



Confirmation

Eurofins Product Testing A/S confirms that a sample of a Fire protection coating for concrete surfaces with the name

HENSOTHERM 820KS

supplied by

Rudolf Hensel GmbH

showed low VOC contents in a test specified in LEED 2009 credit EQ c4.2 (paints and coatings).

VOC contents were below the limit value specified in SCAQMD rule 1113 as 350 grams VOC minus water per liters for "Fire-Proofing Coatings".

The test has been performed in December 2012, test report no. G17860C.

Volatiles content was calculated by Eurofins.
Water content was given by the client.
Content of exempt compounds was set to zero.
Solids content was determined by Eurofins.

With this confirmation, use of product may qualify for fulfilment of LEED 2009 credit EQ c4.2 (paints and coatings).

28 August 2013

Thomas Neuhaus
Head of product emission test centre

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com