



**1121-CPR-JA5039**

**SILVERSEAL®  
HS COMPOUND**

**1. Unique identification code of product-type:**

HSC

**2. Type, Batch or serial number as required pursuant to Article 11(4):**

See ETA 14/0280 : See batch number displayed on product.

**3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:**

Fire Stopping and Sealing Products for Penetration Seals, See ETA 14/0280

<b>Cable Penetrations</b>	Insulated Cables	The field of application has to comply with the content of ETA 14/0280
<b>Pipe Penetrations</b>	Insulated metal pipe	The field of application has to comply with the content of ETA 14/0280

**4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):**

FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

**5. Authorized representative: N/A**

**6. System or systems of assessment and verification of performance of the construction product as set out in Annex V: AVCP - System 1**

**7. Harmonized standard: N/A**

**8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:**

Warrington Certification Limited issued European Technical Approval - ETA 14/0280 on the basis of ETAG 026 part 1 General June 2013 fire protection products & ETAG 026 part 2 August 2011 fire stopping and fire sealing products & issued certificate of conformity 1121-CPR-JA5066

**9. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
<b>Reaction to Fire</b>	Class F According to EN13501-1,
<b>Resistance to Fire</b>	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 14/0280 clause 3.2 - Annex C
<b>Dangerous Substances</b>	See ETA 14/0280 Clause 3.5
<b>Airbourne Sound Insulation</b>	Tested in accordance with EN ISO 10140-2010 & EN ISO 717-1 See TDS STD Compound - Rw (C;Ctr) = 50 (-1; -4) dB
<b>Service &amp; Durability</b>	Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024, Clause 3.12

**10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer by:



14/09/2015

**C. Atkinson - Managing Director**



14/09/2015

**L. Peach - Technical Manager**



FSi Limited,  
Westminster Industrial Estate,  
Tamworth Road, Measham,  
DE12 7DS, UK.



Tel: +44 (0) 1530 515130  
Fax: +44 (0) 1530 273564  
Email: sales@fsiltd.com  
Website: www.fsiltd.com

